



Reference No. SE-S-2200288R1

Room thermostat

Type designation: EB-105, EB-55 **Certificate holder:** EBECO AB

Lärjeågatan 11 415 02 Göteborg

Sweden

The product complies with EN 60730-1:2016+A1

the standard(s): EN IEC 60730-2-9:2019+A1+A2

Date of expiry: 07 March, 2027

EU Directive information: According to the principle of presumption of conformity, this certificate

constitutes support for an EU Declaration of Conformity to the Low

Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 15 August, 2023

Quan Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2200288R1

_	•			_	
. I. O	chi	116	വി	na	ta:
	CILI	116	aı ı	υa	La.

Type designation EB-105, EB-55
Rated voltage (V) 230V AC
Rated current (A) 16A
Frequency (Hz) 50/60Hz
Class Class II
IP-Class IP21

Number of terminals 7 screw terminals for max 2,5mm²

Trademark EBECO \$\footnote{\text{EBECO}} \footnote{\text{SI}}

Test Report 2101938STO-001, 2303935STO-001

Product information Independently mounted room thermostat for 60mm wall box.

Feature of automatic action: 1.B (micro-disconnection), 100000 (A),

600 (M). PTI 175, Pollution degree 2. T40, Uimp: 4000V,

Overvoltage category III.

Manufacturing Sites: Dongguan Value Tech Industrial Limited

Room301, No.7, Tuanjie Road, Shutian,

Humen Town, Dongguan City,

Guangdong Province,

523929

China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued S-certificate with ref. No 2200288, dated 07 March 2022. A new certificate has been issued due factory location change and an alternative component was added.

	Lotost		
Certification Body:	Intertek Semko AB, Product Certification	Place:	Kista - Stockholm
Signed:	anan Li	Date:	15 August, 2023
	Quan Li		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2